

Message

**From:** Burns, Nancy (POL) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=NANCY.BURNS640]  
**Sent:** 8/28/2012 5:00:45 PM  
**To:** Hanchett, James (DPH) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=MassMail-01/cn=Recipients/cn=James.Hanchett]  
**CC:** Gagnon, Kenneth (POL) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Kenneth.gagnon090]  
**Subject:** RE: Shower Testing

Hi Jim. The April 18th test would be a Q2 test. If you want to test them prior to Oct 1, that would be a Q3 test. The October test could be a Q4 test. They just need to be tested sometime in the quarter. You can move them to whatever schedule you are most comfortable with as long as the test takes place within the time frame.

Q1 Jan 1 till March 31 Q2 April 1 to June 30 Q3 July 1 to Sept 30 Q4 Oct 1 to Dec 31.

You can decide how to work it out with the university. Also, when you test them it is not necessary to measure the gallons/minute. We just confirm that the water is flowing and the shower works. It is good to run them a little to remove sediment and the like from the normally unused lines. Call me if you want to discuss.

Nancy  
978-451-3545  
[nancy.burns@Massmail.state.ma.us](mailto:nancy.burns@Massmail.state.ma.us)

**From:** Hanchett, James (DPH)  
**Sent:** Tuesday, August 28, 2012 9:38 AM  
**To:** Burns, Nancy (POL)  
**Subject:** Shower Testing

Hi Nancy,

I got in touch with the personnel in UMass Environmental Health & Safety who test the safety showers. They can test twice per year and loan us the equipment for the other times. The last time showers were tested was 4/18/12 and we are due in October for another test. Do you want me to try to get on your quarterly schedule September, December, March and June?

Jim Hanchett  
Department of State Police  
Amherst Drug Lab  
Room N251 Morrill I  
637 North Pleasant Street  
Amherst, MA 01003  
Phone 413-545-2607  
Fax 413-545-2608  
Cell [REDACTED]

